



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

McGraw Central School District

Project Name: Drinking Water

Tom McCall
10 West Academy Street
McGraw, NY 13101

Project / PO Number: N/A
Received: 09/29/2016 10:00
Reported: 11/13/2016 11:42

Analytical Testing Parameters

Client Sample ID: ES-GB-A
Lab Sample ID: J6J0121-01
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 05:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00347	0.0150	0.00100	mg/L		10/19/16 0800	10/25/16 1943

Analytical Testing Parameters

Client Sample ID: ES-GB-B
Lab Sample ID: J6J0121-02
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 05:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00375	0.0150	0.00100	mg/L		10/19/16 0800	10/25/16 1944

Analytical Testing Parameters

Client Sample ID: ES-GB-C
Lab Sample ID: J6J0121-03
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 05:56

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00418	0.0150	0.00100	mg/L		10/19/16 0800	10/25/16 1944



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Analytical Testing Parameters

Client Sample ID: ES-GB-D
Lab Sample ID: J6J0121-04
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 05:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00352, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 1946.

Analytical Testing Parameters

Client Sample ID: ES-GB-E
Lab Sample ID: J6J0121-05
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 05:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00304, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 1947.

Analytical Testing Parameters

Client Sample ID: ES-45-A
Lab Sample ID: J6J0121-06
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 06:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00789, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 1949.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Analytical Testing Parameters

Client Sample ID: ES-54-A
Lab Sample ID: J6J0121-07
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 06:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0105, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 1950

Analytical Testing Parameters

Client Sample ID: ES-64-A
Lab Sample ID: J6J0121-08
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 06:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00635, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 1950

Analytical Testing Parameters

Client Sample ID: ES-64-B
Lab Sample ID: J6J0121-09
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 06:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00508, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 1951



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Analytical Testing Parameters

Client Sample ID: ES-R101A-1
Lab Sample ID: J6J0121-10
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 06:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00669, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 1952

Analytical Testing Parameters

Client Sample ID: ES-20-A
Lab Sample ID: J6J0121-11
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 06:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00588, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 1952

Analytical Testing Parameters

Client Sample ID: ES-23-A
Lab Sample ID: J6J0121-12
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 06:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00195, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 1954



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Analytical Testing Parameters

Client Sample ID: ES-24-A
Lab Sample ID: J6J0121-13
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 06:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00456, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 1955.

Analytical Testing Parameters

Client Sample ID: ES-25-A
Lab Sample ID: J6J0121-14
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 06:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00706, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 1956.

Analytical Testing Parameters

Client Sample ID: ES-26-A
Lab Sample ID: J6J0121-15
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 06:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00804, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 1956.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Analytical Testing Parameters

Client Sample ID: ES-27-A
Lab Sample ID: J6J0121-16
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 06:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00531, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 1958.

Analytical Testing Parameters

Client Sample ID: ES-28-A
Lab Sample ID: J6J0121-17
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 06:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00579, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 1959.

Analytical Testing Parameters

Client Sample ID: ES-11-A
Lab Sample ID: J6J0121-18
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 05:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00720, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 1959.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Analytical Testing Parameters

Client Sample ID: ES-12-A
Lab Sample ID: J6J0121-19
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 05:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00828, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2000

Analytical Testing Parameters

Client Sample ID: ES-14-A
Lab Sample ID: J6J0121-20
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 06:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00404, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2002

Analytical Testing Parameters

Client Sample ID: ES-15-A
Lab Sample ID: J6J0121-21
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 06:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00546, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2003



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Analytical Testing Parameters

Client Sample ID: ES-16-A
Lab Sample ID: J6J0121-22
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 06:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00307, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2003

Analytical Testing Parameters

Client Sample ID: ES-17-A
Lab Sample ID: J6J0121-23
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 06:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00363, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2004

Analytical Testing Parameters

Client Sample ID: ES-18-A
Lab Sample ID: J6J0121-24
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 06:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00375, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2005



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Analytical Testing Parameters

Client Sample ID: ES-19-A
Lab Sample ID: J6J0121-25
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 06:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00360, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2005

Analytical Testing Parameters

Client Sample ID: ES-3-A
Lab Sample ID: J6J0121-26
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 05:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00664, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2007

Analytical Testing Parameters

Client Sample ID: ES-4-A
Lab Sample ID: J6J0121-27
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 05:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00613, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2008



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Analytical Testing Parameters

Client Sample ID: ES-5-A
Lab Sample ID: J6J0121-28
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 05:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00235, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2010

Analytical Testing Parameters

Client Sample ID: ES-6-A
Lab Sample ID: J6J0121-29
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 05:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00660, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2011

Analytical Testing Parameters

Client Sample ID: ES-7-A
Lab Sample ID: J6J0121-30
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 05:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00710, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2011



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Analytical Testing Parameters

Client Sample ID: ES-8-A
Lab Sample ID: J6J0121-31
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 05:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00980, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2012

Analytical Testing Parameters

Client Sample ID: ES-9-A
Lab Sample ID: J6J0121-32
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 05:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00478, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2013

Analytical Testing Parameters

Client Sample ID: ES-10-A
Lab Sample ID: J6J0121-33
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 05:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00558, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2013



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Analytical Testing Parameters

Client Sample ID: HS-42-1
Lab Sample ID: J6J0121-34
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00187, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2014.

Analytical Testing Parameters

Client Sample ID: HS-42-2
Lab Sample ID: J6J0121-35
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00231, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2015.

Analytical Testing Parameters

Client Sample ID: HS-42-A
Lab Sample ID: J6J0121-36
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0240, 0.0150, 0.00100, mg/L, G, 10/19/16 0800, 10/25/16 2018.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Analytical Testing Parameters

Client Sample ID: HS-42-B
Lab Sample ID: J6J0121-37
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0171, 0.0150, 0.00100, mg/L, G, 10/19/16 0800, 10/25/16 2019

Analytical Testing Parameters

Client Sample ID: HS-42-C
Lab Sample ID: J6J0121-38
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0248, 0.0150, 0.00100, mg/L, G, 10/19/16 0800, 10/25/16 2019

Analytical Testing Parameters

Client Sample ID: HS-34A-A
Lab Sample ID: J6J0121-39
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00500, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2020



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Analytical Testing Parameters

Client Sample ID: HS-34A-B
Lab Sample ID: J6J0121-40
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00617, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2020.

Analytical Testing Parameters

Client Sample ID: HS-25-A
Lab Sample ID: J6J0121-41
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0551, 0.0150, 0.00100, mg/L, G, 10/19/16 0800, 10/25/16 2021.

Analytical Testing Parameters

Client Sample ID: HS-35-B
Lab Sample ID: J6J0121-42
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0282, 0.0150, 0.00100, mg/L, G, 10/19/16 0800, 10/25/16 2022.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Analytical Testing Parameters

Client Sample ID: HS-21A-A
Lab Sample ID: J6J0121-43
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0102, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2022

Analytical Testing Parameters

Client Sample ID: HS-21A-B
Lab Sample ID: J6J0121-44
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00677, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2023

Analytical Testing Parameters

Client Sample ID: HS-21B-A
Lab Sample ID: J6J0121-45
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0212, 0.0150, 0.00100, mg/L, G, 10/19/16 0800, 10/25/16 2024



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Analytical Testing Parameters

Client Sample ID: HS-21B-B
Lab Sample ID: J6J0121-46
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0231, 0.0150, 0.00100, mg/L, G, 10/19/16 0800, 10/25/16 2027

Analytical Testing Parameters

Client Sample ID: HS-22-A
Lab Sample ID: J6J0121-47
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0377, 0.0150, 0.00100, mg/L, G, 10/19/16 0800, 10/25/16 2028

Analytical Testing Parameters

Client Sample ID: HS-23-A
Lab Sample ID: J6J0121-48
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0292, 0.0150, 0.00100, mg/L, G, 10/19/16 0800, 10/25/16 2028



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Analytical Testing Parameters

Client Sample ID: HS-24-A
Lab Sample ID: J6J0121-49
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0278, 0.0150, 0.00100, mg/L, G, 10/19/16 0800, 10/25/16 2029

Analytical Testing Parameters

Client Sample ID: HS-25-A
Lab Sample ID: J6J0121-50
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.101, 0.0150, 0.00100, mg/L, GE, 10/19/16 0800, 10/25/16 2030

Analytical Testing Parameters

Client Sample ID: HS-18J-A
Lab Sample ID: J6J0121-51
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00686, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2030



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Analytical Testing Parameters

Client Sample ID: HS-18J-B
Lab Sample ID: J6J0121-52
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00637, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2031

Analytical Testing Parameters

Client Sample ID: HS-18K-A
Lab Sample ID: J6J0121-53
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00650, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2032

Analytical Testing Parameters

Client Sample ID: HS-18K-B
Lab Sample ID: J6J0121-54
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00512, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2034



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Analytical Testing Parameters

Client Sample ID: HS-19A-B
Lab Sample ID: J6J0121-55
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0113, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2034.

Analytical Testing Parameters

Client Sample ID: HS-19A-A
Lab Sample ID: J6J0121-56
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0226, 0.0150, 0.00100, mg/L, G, 10/19/16 0800, 10/25/16 2036.

Analytical Testing Parameters

Client Sample ID: HS-19J-A
Lab Sample ID: J6J0121-57
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0704, 0.0150, 0.00100, mg/L, G, 10/19/16 0800, 10/25/16 2037.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Analytical Testing Parameters

Client Sample ID: HS-1-A
Lab Sample ID: J6J0121-58
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0286, 0.0150, 0.00100, mg/L, G, 10/19/16 0800, 10/25/16 2037

Analytical Testing Parameters

Client Sample ID: HS-2-A
Lab Sample ID: J6J0121-59
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0205, 0.0150, 0.00100, mg/L, G, 10/19/16 0800, 10/25/16 2038

Analytical Testing Parameters

Client Sample ID: HS-3-A
Lab Sample ID: J6J0121-60
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00977, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2039



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Analytical Testing Parameters

Client Sample ID: HS-7D-A
Lab Sample ID: J6J0121-61
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0208, 0.0150, 0.00100, mg/L, G, 10/19/16 0800, 10/25/16 2039

Analytical Testing Parameters

Client Sample ID: HS-7E-A
Lab Sample ID: J6J0121-62
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00903, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2041

Analytical Testing Parameters

Client Sample ID: HS-7G-A
Lab Sample ID: J6J0121-63
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00748, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2042



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Analytical Testing Parameters

Client Sample ID: HS-7G-B
Lab Sample ID: J6J0121-64
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00670, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2043

Analytical Testing Parameters

Client Sample ID: HS-10-A
Lab Sample ID: J6J0121-65
Sample Type: Grab

Collected By: TM-CLIENT
Collection Date: 09/29/16
Collection Time: 07:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00771, 0.0150, 0.00100, mg/L, 10/19/16 0800, 10/25/16 2043

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
E: Estimated result
MDL: Minimum Detection Limit
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Table with 4 columns: Item, Yes, Item, Yes. Rows: Custody Seals Intact and/or No Evidence of Tampering, COC/Labels Agree, Received on Ice (or not required)



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0121

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795
Microbac Laboratories, Inc. - Chicagoland
NY Lab ID No: 12006
PA DEP ID: 68-04863

New York State Department of Health
New York State Department of Health
Pennsylvania Department of Environmental Protection

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Handwritten signature of Michael Fifield

Michael Fifield For Eric Monsen
Field Manager
11/13/2016 11:42

Go Green: Contact Eric Monsen to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Eric Monsen, Project Manager at eric.monsen@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

3024 Buck Drive
 Corland NY 13048
 Phone:(607)763-3703 Fax:(607)763-3416
 NY #60795, EPA #NY00885

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on ice

Workorder #



J6J0121

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	McGraw Central School					Ice:	YES NO
Address:	10 West Academy St					Cooler:	YES NO
Contact:	McGraw NY 13101					Sample Temp:	
Phone:	607-836-3614					Cooler Seal:	YES NO
Project:	Drinking Water					Flickup:	YES NO
Quote ID:		PO#:				Dropoff:	C W
Rush TAT Bus. Days:	<2 2-5 6-7 7-10	Date Req.:				Accepted?	YES NO
Released to DOH:	Yes	myan@cofbad-co.org				Container Material:	
Email Results:	Yes	truce1@mcgrawschools.org				Container Size(In Mi)	
Fax Results:	Yes					Preservative	
Sample Information		Matrix		Number of Containers for Analysis Requested		Comments/Field Data	
Description/Location	Date	Time	Initial	Type			
1 ES-GB-A	9/29/16	5:55 PM	TM				
2 ES-GB-B	9/29/16	5:55 PM	TM				
3 ES-GB-C	9/29/16	5:56 PM	TM				
4 ES-GB-D	9/29/16	5:57 PM	TM				
5 ES-GB-E	9/29/16	5:58 PM	TM				
6							
7							
8							
Print Name and Company		Signature		Date/Time		Comments	
Sample: Dawn Hall - McGraw USD		[Signature]		9/29/16 9:00 AM			
Received: Dawn Buchanan		[Signature]		9/29/16 10:00 AM			
Received:							
Received:							
Received:							

3821 Buck Drive
 Cortland NY 13045
 Phone: (607) 753-3705 Fax: (607) 753-3416
 NY #10795, EPA #NY00085

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on Ice

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	McGraw Central Schools					Ice:	YES NO
Address:	10 West Reading St McGraw NY 13161					Cooler:	YES NO
Contact:	Tom McCall					Sample Temp:	
Phone:	607-836-3614					Cooler Seal:	YES NO
Project:	Drinking Water					Pickup:	YES NO
Quote ID:						Dropoff:	C W
Rush TAT Bus. Days:	<2 2-5 6-7 7-10					Accepted?	YES NO
Release to DOH: Yes						Container Material:	
Email Results: Yes	amccall@mcgrawcentral.org					Container Size (in Mil):	
Fax Results: Yes						Preservative:	
						Comments/Field Data	

Sample Information		Matrix		Number of Containers for Analysis Requested		Date/Time	Signature	Comments
Description/Location	Date	Time	Initial					
ES-45-A	9/29/16	6:29 AM	TM			9/29/16 8:00 AM		
ES-54-A	9/29/16	6:00 AM	TM					
ES-64-A	9/29/16	6:15 AM	TM					
ES-64-B	9/29/16	6:16 AM	TM					
ES-R101A-A	9/29/16	6:02 AM	TM					

Print Name and Company	Signature	Date/Time	Comments
Tom McCall - McGraw (SD)	<i>[Signature]</i>	9/29/16 8:00 AM	
Deni Brachman	<i>[Signature]</i>	9/29/16 10:00 AM	

3024 Buck Drive
 Cortland NY 13048
 Phone: (607) 763-3408 Fax: (607) 763-3418
 NY #10795, EPA #NY00325

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information				Billing/Invoice:			
Name:	McBain Central School			PO#:			
Address:	10 West Academy St McGraw NY 13101			Date Req.:			
Contact:	DMMcCall			Release to DOH: Yes	Morgan Environmental Co. Inc		
Phone:	607-836-3614			Email Results:	Yes tmccalle@mgrenv.com		
Project:	Drinking Water			Fax Results:	Yes		
Quote ID:							

Sample Information				Receiving Info (Lab Use Only)			
Description	Location	Date	Time	Initial	Matrix Type	Ice:	YES NO
1	ES-20-A	9/29/16	6:13 AM	Tm		Cooler:	YES NO
2	ES-23-A	9/29/16	6:20 AM	Tm		Sample Temp:	YES NO
3	ES-24-A	9/29/16	6:22 AM	Tm		Cooler Seal:	YES NO
4	ES-25-A	9/29/16	6:22 AM	Tm		Pickup:	YES NO
5	ES-26-A	9/29/16	6:23 AM	Tm		Dropoff:	C W
6	ES-27-A	9/29/16	6:25 AM	Tm		Accepted?	YES NO
7	ES-28-A	9/29/16	6:27 AM	Tm		Container Material:	
8						Container Size (in MI)	
						Preservative	
						Comments/Field Data	

Print Name and Company		Signature	Date/Time
Sampled:	Tom McCall - McGraw (SD)	<i>[Signature]</i>	9/29/16 8:00 AM
Received:	Den Boucham	<i>[Signature]</i>	9/29/16 10:00 AM
Received:			
Received:			
Received:			

3021 Buck Drive
 Conland NY 13048
 Phone (007)703-3405 Fax (007)703-3416
 NY #10785, EPA #NY00035

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	McGrath Central School					Ice:	YES NO
Address:	10 West Henckens St					Cooler:	YES NO
Contact:	Mr. Graw NY 13101					Sample Temp:	
Phone:	607-836-3614					Container Seal:	YES NO
Project:	Drinking Water					Pickup:	YES NO
Quote ID:						Dropoff:	C W
Rush TAT Bus. Days:	<2 2-5 6-7 7-10	Date Req.:				Accepted?	YES NO
Release to DOH:	Yes	myan@conland-ny.org				Container Material	
Email Results:	Yes	AmcCall@mcgrathschools.org				Container Size (in Mi)	
Fax Results:	Yes					Preservative	
Sample Information		Number of Containers for Analysis Requested		Comments/Field Data			
Description/Location	Date	Time	Initial	Matrix Type			
1 ES-3-A	9/29/16	5:38 AM	TM				
2 ES-4-A	9/29/16	5:41 AM	TM				
3 ES-5-A	9/29/16	5:42 AM	TM				
4 ES-6-A	9/29/16	5:44 AM	TM				
5 ES-7-A	9/29/16	5:45 AM	TM				
6 ES-8-A	9/29/16	5:47 AM	TM				
7 ES-9-A	9/29/16	5:48 AM	TM				
8 ES-10-A	9/29/16	5:49 AM	TM				
Print Name and Company		Signature		Date/Time		Comments	
Sample: Tom McCall - mcgraw C/D		[Signature]		9/29/16 8:00am			
Received: Dan Beckhorn		[Signature]		9/29/16 11:00am			
Received:							
Received:							
Received:							

3021 Birch Drive
 Cortland NY 13845
 Phone: (607) 768-3408 Fax: (607) 768-3416
 NY #10705, EPA #NY00285

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on Ice

NY Workorder #

Client Information		Billing/Invoice:	
Name:	McGraw Central School		
Address:	10 West Actonway ST McGraw NY 13101		
Contact:	Tom McCall		
Phone:	607-836-3614		
Project:	Drinking water -		
Quote ID:		PO#:	
Rush TAT Bus. Days:	< 2-5 6-7 7-10	Date Req.:	
Release to DOH:	Yes	myper@corland-ny.org	
Email Results:	Yes	tomcall@mcgraw-schools.org	
Fax Results:	Yes		

Sample Information				Matrix Type	
Description/Location	Date	Time	Initial		
1 HS-42-1	9/24/16	7:38 AM	TM		
2 HS-42-2	9/29/16	7:39 AM	TM		
3 HS-42-A	9/29/16	7:39 AM	TM		
4 HS-42-B	9/29/16	7:39 AM	TM		
5 HS-42-C	9/29/16	7:40 AM	TM		
6					
7					
8					

Receiving Info (Lab Use Only)		Analysis Requested		Comments	
Ice:	YES NO				
Cooler:	YES NO				
Sample Temp:					
Cooler Sent:	YES NO				
Pickup:	YES NO				
Dropoff:	C W				
Accepted?	YES NO				
Container Material:					
Container Size (in Mil)					
Preservative:					
Common/Field Data					

Print Name and Company	Signature	Date/Time
Sampled: Tom McCall - McGraw CSD	<i>Tom McCall</i>	9/29/16 8:00 AM
Received: Tom Beuchtel	<i>Tom Beuchtel</i>	9/29/16 10:00 AM
Received:		
Received:		
Received:		

3021 Buck Drive
 Cortland NY 13045
 Phone (607) 763-3408 Fax (607) 768-3416
 NY #10795, EPA #NY000885

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on Ice

Workorder #

Client Information		Billing/Invoice:		Analytels Requested		Receiving Info (Lab Use Only)		
Name:	McGraw Central School					Ice:	YES NO	
Address:	10 West Academy St McGraw, NY 13101					Cooler:	YES NO	
Contact:	Tom McCall					Sample Temp:	YES NO	
Phone:	607-836-3614					Cooler Seal:	YES NO	
Project:	Drinking Water					Pickup:	YES NO	
Quote ID:						Dropoff:	C W	
Rush TAT Bus. Days:	<2 2-5 6-7 7-10	Date Req.:				Accepted?	YES NO	
Release to DOH:	Yes	Person @ Cortland - Co. #				Container Material		
Email Results:	Yes	tmccall@mcgrawcschools.org				Container Size (in Mi)		
Fax Results:	Yes					Preservative		
Sample Information				Number of Containers for Analytels Requested				Comments/Field Data
Description/Location	Date	Time	Initial	Matrix Type				
1 HS-34A-A	9/29/16	7:22 AM	TM					
2 HS-34A-B	9/29/16	7:22 AM	TM					
3 HS-35-A	9/29/16	7:23 AM	TM					
4 HS-35-B	9/29/16	7:23 AM	TM					
5								
6								
7								
8								

Print Name and Company: Tom McCall - McGraw CSO
 Signature: [Signature]
 Date/Time: 9/29/16 8:00 AM
 Date/Time: 9/29/16 10:00 AM
 Received: [Signature]
 Received: [Signature]
 Received: [Signature]
 Received: [Signature]

3021 Buck Drive
 Cortland NY 13846
 Phone: (607) 763-3408 Fax: (607) 763-3476
 NY #10796, EPA #NY000285

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on Ice

MNY Workorder #

Client Information				Billing/Invoice:			
Name: <u>McGraw Central School</u>				Address: <u>10 West Academy St</u>			
Address: <u>McGraw, NY 12101</u>				Contact: <u>Tom McCall</u>			
Phone: <u>607-836-3614</u>				Project: <u>Drinking water</u>			
Quote ID: _____				PO#: _____			
Rush TAT Bus. Days: < 2-5 6-7 7-10				Date Req.: _____			
Release to DOH: <input checked="" type="checkbox"/> <u>Yes</u>				Email Results: <input checked="" type="checkbox"/> <u>Yes</u>			
Email Results: <u>Yes</u>				Fax Results: <input checked="" type="checkbox"/> <u>Yes</u>			
Email Results: <u>Yes</u>				Fax Results: <input checked="" type="checkbox"/> <u>Yes</u>			
Sample Information							
1	Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested	Comments
1	HS-21A-A	9/29/16	7:10 PM	Tm			
2	HS-21A-B	9/29/16	7:16 AM	Tm			
3	HS-21B-A	9/29/16	7:28 AM	Tm			
4	HS-21B-B	9/29/16	7:28 AM	Tm			
5	HS-22-A	9/29/16	7:35 AM	Tm			
6	HS-23-A	9/29/16	7:34 AM	Tm			
7	HS-24-A	9/29/16	7:32 AM	Tm			
8	HS-25-A	9/29/16	7:31 AM	Tm			
Samples: <u>Tom McCall - McGraw USD</u>						Signature: <u>[Signature]</u>	
Received: <u>Don Brachem</u>						Date/Time: <u>9/29/16 8:00am</u>	
Received: _____						Date/Time: <u>9/29/16 10:00am</u>	
Received: _____						Date/Time: _____	
Received: _____						Date/Time: _____	

3621 Buck Drive
 Cortland NY 13846
 Phone: (607) 763-3408 Fax: (607) 763-3416
 NY #10795, EPA #NY000835

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on Ice

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	McGraw Central School					Ice:	YES NO
Address:	10 West Academy St McGraw NY 13841					Cooler:	YES NO
Contact:	Tom McCall					Sample Temp:	YES NO
Phone:	607-836-3614					Cooler Seal:	YES NO
Project:	Drinking Water					Pickup:	YES NO
Quote ID:						Dropoff:	C W
						Accepted?	YES NO
Rush TAT Bus. Days:	< 2-5 6-7 7-10	Date Req.:				Container Material:	
Release to DOH: Yes	<input checked="" type="checkbox"/>	mryan@contland-ny.org				Container Size (in Mi):	
Email Results: Yes	<input checked="" type="checkbox"/>	tmcall@mcgrawschools.org				Preservative:	
Fax Results: Yes	<input checked="" type="checkbox"/>					Comments/Field Data	

Sample Information		Matrix Type		Number of Containers for Analysis Requested		Date/Time		Comments	
Description/Location	Date	Time	Initial						
1 HS-18J-A	9/29/16	7:05 AM	TM						
2 HS-18J-B	9/29/16	7:05 AM	TM						
3 HS-18K-A	9/29/16	7:06 AM	TM						
4 HS-18K-B	9/29/16	7:06 AM	TM						
5 HS-19A-B	9/29/16	7:02 AM	TM						
6 HS-19A-A	9/29/16	7:01 AM	TM						
7 HS-19JA	9/29/16	7:00 AM	TM						
8	9/29/16								

Print Name and Company	Signature	Date/Time	Comments
Tom McCall - McGraw CSD	<i>[Signature]</i>	9/29/16 8:00	
Tom McCall	<i>[Signature]</i>	9/29/16 11:00	
Received:			
Received:			
Received:			
Received:			

